

STATE OF VERMONT
PUBLIC SERVICE BOARD

Docket No. 7603

Petition of Village of Lyndonville Electric)
Department for a certificate of public good pursuant)
to 30 V.S.A. § 248(j) authorizing the reconductoring)
of 3 miles of 34.5 kV transmission line in Lyndon,)
Vermont)

Entered: 6/4/2010

CERTIFICATE OF PUBLIC GOOD ISSUED
PURSUANT TO 30 V.S.A. SECTION 248

IT IS HEREBY CERTIFIED that the Public Service Board of the State of Vermont this day found and adjudged that the reconductoring of 3 miles of 34.5 kV transmission line in Lyndon, Vermont, by the Village of Lyndonville Electric Department ("LED"), in accordance with the evidence and plans submitted in this proceeding (the "Project"), will promote the general good of the State, subject to the following conditions:

1. Construction, operation, and maintenance of the Project shall be in accordance with the plans and evidence submitted in this proceeding.
2. Prior to commencement of site preparation for and construction of the Project, LED shall file with the Public Service Board ("Board") confirmation that it has obtained all required permits and copies of the same shall have been filed with the Board.
3. This Certificate of Public Good shall not be transferred without prior approval of the Board.
4. In order to minimize any wetland crossing associated with project construction, LED shall first investigate using alternate routes across adjoining properties. In cases where alternate routes are not feasible, LED shall use rubber swamp mats, approximately 16 feet wide by 4 feet long, within the right-of-way. The mats shall be placed sequentially beginning at the edge of the wetland and shall be left in place for no more than four weeks. Any soil disturbance associated with the mat placement shall be mulched with weed-free straw upon removal of the mats.

Dated at Montpelier, Vermont, this 4th day of June, 2010.

<u>James Volz</u>)	
)	PUBLIC SERVICE
)	
<u>David C. Coen</u>)	BOARD
)	
)	OF VERMONT
<u>John D. Burke</u>)	

OFFICE OF THE CLERK

FILED: June 4, 2010

ATTEST: s/ Susan M. Hudson
Clerk of the Board

NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or in writing) of any apparent errors, in order that any necessary corrections may be made. (E-mail address: psb.clerk@state.vt.us)